

**WEBINAR**

**TVP**  **SOLAR**

**Hubs4Circularity**  
COMMUNITY OF PRACTICE

# FROM DESIGN TO IMPLEMENTATION: SOFTWARE TOOLS IN DISTRICT HEATING

A CASE OF THESEUS AND HURRICANE PROJECT

**SESSION 2**

**PERFORMANCE ASSESSMENT AND  
OPTIMIZATION OF SDHC SYSTEMS**



Funded by the  
European Union



Michele Musto, Project Engineer, TVP Solar SA  
Dimitris Papageorgiou, Innovation Funding Manager, TVP Solar SA  
11 March 2026

# Performance assessment of SDH Systems



## EN ISO 24194

### Power Check according to ISO 24194:2022

Plant SIG  
Included arrays Sig

Power Check fulfilled:

Ratio measured / estimated power = 104.1%  
This takes a combined safety factor  $f_{\text{safe}} = 0.86$  into account.



Notes  
The minimum number of intervals (20, defined in ISO 24194:2022) has been reached: n=859 intervals found, each 1 hour long.  
Data from 2023-01-01 12:03 (UTC+1) to 2026-01-06 07:49 (UTC+1).

Power Check according to ISO 24194:2022  
Algorithm details: Formula: 1. Wind: Not used. Averaging mode: Extended.

### Daily Yield Method Report - ISO 24194:2022

Owner of Plant:	SIG		Check done by:	TVP Solar SA										
Mesuring Period:	01/08/2025 to 31/08/2025		Date:	01/09/2025										
Level of Check:	III		Equation used:	(20)										
Input data Collector			Input data system											
Manufacturer:	TVP Solar		Location Name	Geneve										
Collector Name:	MT-Power V4		Longitude	6.10°										
Certification type:	Solar Keymark		Latitude	46.21°										
Certificate No.:	011-7S1890F		Agf:	[m <sup>2</sup> ]										
Parameters			w/S	[ ]	55.71%									
- Ag:	[m <sup>2</sup> ]	1.96	Vpipe:	[m <sup>2</sup> ]	1.61									
- n0,hem:		0.732	Lpipe:	[m]	870									
- n0,b:		-	fSH:		0.98									
- Kd:		0.95	fsafe:		0.9									
- Khem,av:		0.9785	Project TVP ID: 2018_052											
- a1,dQ:	[W/(m <sup>2</sup> K)]	0.5												
- TdQ (a2):	[W/(m <sup>2</sup> K <sup>2</sup> )]	0.006												
- Cl/Ag (a5):	[μ/(m <sup>2</sup> K)]	15320												
Date	Time start	Time End	H_beam [kWh/m <sup>2</sup> ]	B_global_tilted [kWh/m <sup>2</sup> ]	T_mean_fluid [°C]	T_mean_fluid_start [°C]	T_mean_fluid_end [°C]	T_mean_fluid_se [°C]	pm [kg/m <sup>3</sup> ]	c_p_fluid [kJ/kg·K]	Q_est_system [MWh]	Q_measured_system [MWh]	Performance Energy (PE) ratio	Performance Energy (PE) ratio
2025-08-01	2025-08-01 10:33:00	2025-08-01 17:39:00	4.09	576.70	77.34	76.34	76.14	76.24	982.93	3.98	1.77	2.02	1.14	114.2%
2025-08-02	2025-08-02 10:35:00	2025-08-02 18:15:00	4.81	627.86	77.91	80.06	72.09	76.07	982.53	3.98	2.11	2.28	1.08	108.1%
2025-08-03	2025-08-03 10:44:00	2025-08-03 16:56:00	4.53	731.36	77.54	75.10	72.83	73.96	982.80	3.98	2.01	2.20	1.10	109.5%
2025-08-04	2025-08-04 10:47:00	2025-08-04 17:47:00	5.00	714.85	76.87	74.63	73.57	74.10	983.26	3.98	2.24	2.41	1.08	107.6%
2025-08-05	2025-08-05 10:42:00	2025-08-05 17:54:00	4.92	682.96	77.89	72.97	74.48	73.72	982.55	3.98	2.19	2.35	1.07	106.9%
2025-08-06	2025-08-06 11:10:00	2025-08-06 17:33:00	4.28	670.08	75.80	75.42	73.29	74.36	983.99	3.98	1.89	1.95	1.03	102.9%
2025-08-07	2025-08-07 10:44:00	2025-08-07 18:13:00	6.38	852.06	78.49	77.19	72.25	74.72	982.14	3.98	2.95	3.09	1.05	104.9%
2025-08-08	2025-08-08 10:45:00	2025-08-08 18:07:00	5.72	776.42	78.29	76.01	72.61	74.31	982.28	3.98	2.64	2.81	1.06	106.5%
2025-08-09	2025-08-09 10:44:00	2025-08-09 17:57:00	5.52	764.43	78.20	75.04	72.88	73.96	982.34	3.98	2.56	2.75	1.07	107.4%
2025-08-10	2025-08-10 10:44:00	2025-08-10 17:54:00	5.65	788.99	78.40	75.54	72.85	74.20	982.20	3.98	2.61	2.77	1.06	106.2%
2025-08-11	2025-08-11 10:45:00	2025-08-11 17:55:00	5.56	775.65	78.34	74.61	74.12	74.37	982.24	3.98	2.54	2.70	1.07	106.5%
2025-08-12	2025-08-12 10:46:00	2025-08-12 17:50:00	5.40	764.54	78.07	75.51	72.65	74.08	982.43	3.98	2.50	2.68	1.07	107.0%
2025-08-13	2025-08-13 10:48:00	2025-08-13 17:44:00	5.21	751.53	77.75	74.11	73.02	73.57	982.65	3.98	2.40	2.54	1.06	105.7%
2025-08-14	2025-08-14 10:47:00	2025-08-14 16:20:00	4.62	832.96	78.63	76.40	76.15	76.27	982.04	3.98	2.13	2.48	1.17	116.5%
2025-08-15	2025-08-15 10:50:00	2025-08-15 18:38:00	3.86	494.72	78.49	76.17	73.50	74.84	982.14	3.98	1.66	1.92	1.15	115.4%
2025-08-16	2025-08-16 10:52:00	2025-08-16 17:58:00	4.82	678.39	77.44	74.88	71.53	73.20	982.86	3.98	2.19	2.32	1.05	105.5%
2025-08-17	2025-08-17 10:48:00	2025-08-17 17:30:00	5.36	800.16	78.07	73.76	74.30	74.03	982.43	3.98	2.43	2.57	1.06	105.6%
2025-08-18	2025-08-18 10:52:00	2025-08-18 17:35:00	5.58	830.27	78.28	74.62	73.75	74.19	982.28	3.98	2.55	2.72	1.06	106.5%
2025-08-19	2025-08-19 10:44:00	2025-08-19 17:54:00	5.65	788.99	78.40	75.54	72.85	74.20	982.20	3.98	2.61	2.77	1.06	106.2%
2025-08-20	2025-08-20 10:45:00	2025-08-20 18:07:00	5.72	776.42	78.29	76.01	72.61	74.31	982.28	3.98	2.64	2.81	1.06	106.5%
2025-08-21	2025-08-21 10:46:00	2025-08-21 17:50:00	5.40	764.54	78.07	75.51	72.65	74.08	982.43	3.98	2.50	2.68	1.07	107.0%
2025-08-22	2025-08-22 10:56:00	2025-08-22 17:57:00	5.39	768.05	77.80	75.66	71.39	73.53	982.61	3.98	2.43	2.55	1.05	104.9%
2025-08-23	2025-08-23 10:59:00	2025-08-23 17:31:00	4.89	747.78	76.97	76.40	77.27	76.84	983.19	3.98	2.18	2.50	1.15	114.6%
2025-08-24	2025-08-24 10:57:00	2025-08-24 17:36:00	5.51	828.40	78.00	76.78	73.49	75.13	982.47	3.98	2.50	2.75	1.10	110.0%
2025-08-25	2025-08-25 11:00:00	2025-08-25 17:21:00	4.78	752.78	77.40	75.80	71.98	73.89	982.89	3.98	2.17	2.42	1.11	111.4%
2025-08-26	2025-08-26 10:59:00	2025-08-26 17:06:00	4.35	711.17	77.39	75.43	71.95	73.69	982.90	3.98	1.98	2.20	1.11	110.8%
2025-08-27	2025-08-27 10:57:00	2025-08-27 17:36:00	5.51	828.40	78.00	76.78	73.49	75.13	982.47	3.98	2.50	2.75	1.10	110.0%
2025-08-28	2025-08-28 11:00:00	2025-08-28 17:21:00	4.78	752.78	77.40	75.80	71.98	73.89	982.89	3.98	2.17	2.42	1.11	111.4%
2025-08-29	2025-08-29 11:16:00	2025-08-29 16:46:00	2.31	419.31	75.85	72.88	79.13	76.00	983.96	3.98	0.87	1.19	1.36	136.4%
2025-08-30	2025-08-30 11:43:00	2025-08-30 17:47:00	3.54	582.82	77.06	77.91	73.07	75.49	983.12	3.98	1.52	1.85	1.22	121.8%
2025-08-31	2025-08-31 11:02:00	2025-08-31 17:37:00	5.06	768.35	77.87	75.66	73.56	74.61	982.57	3.98	2.28	2.53	1.11	111.1%

5. Procedure for checking the power performance of solar thermal collector fields

6. Procedure for checking the daily yield (Energy Performance) of solar thermal collector fields

# Performance assessment of SDH Systems

## EN ISO 24194 – PE ratio Monitoring

- $Q_{HM,d}$  Daily yield measurement of the heat meter
- $Q_{estimate-sys,d}$  Daily yield estimation of solar thermal system

$$PE_{ratio} = Q_{HM,d} / Q_{estimate-sys,d} \geq 1 \rightarrow \text{Estimate verified}$$

KEY INDICATOR

PE Ratio


$$Q_{HM,d} / Q_{estimate-sys,d}$$

Ratio between the energy measured by the heat meter (SCADA) and the energy estimated under the same boundary conditions (ISO 24194 model).

Performance Target

↑  $\geq 1.0$

(Measured  $\geq$  Estimated)



Illustrative Example

Hypothesis: PE Ratio trend under the same boundary conditions

# Performance assessment of SDH Systems

## Supervisory Control and Data Acquisition (SCADA) System

### SCADA System



#### Real-Time Supervision & HMI

Intuitive graphical interfaces (HMI) to monitor processes in real time, visualize plant status, and access all operational parameters remotely.



#### Data Acquisition & Storage

Continuous collection of data from sensors, motors, and field instrumentation, with historical storage for further analysis and reporting.



#### Remote Device Control


Direct management of actuators such as pumps, control valves, and Variable Frequency Drives (VFDs) to modulate plant operation.




#### Alarm & Event Management

Real-time alerting system for anomalies and critical alarms, enabling operators to intervene promptly and ensure system safety.


### Zonthermiepark Dorkwerd SCADA




East Section Solar Field (Primary Side)



East Section Secondary Side



TES Tank Charging / Discharging Section



Thermal Energy Storage Tank

# Performance assessment of SDH Systems

## Data Analysis Tools

## Data Analysis Tools



### Open-Source Platform

Grafana is a leading standard for data analysis and interactive visualization. It enables the aggregation of metrics from multiple sources into a single, consistent interface.



### Dynamic Dashboards

Creation of customizable dashboards that provide an immediate visual representation of processes, helping to quickly interpret large volumes of operational data.



### Query & Alerting

Advanced capability to run complex queries and set automatic alerts on critical thresholds, enabling proactive monitoring of anomalies.



### Decision Support

Facilitates the identification of trends, inconsistencies, and hidden correlations, supporting operators in improving process efficiency and optimizing performance.

## Zonthermiepark Dorkwerd – Grafana Data Analysis



# Optimization of SDH Systems

## Operating Logic & Functional Design Specification



The control logic represent the operational philosophy of the solar thermal plant  
It defines how the system automatically manages the different operating conditions.





# Optimization of SDH Systems

## Integrated Control Loops




# Optimization of SDH Systems

## Performance Examples of Real SDH TVP's Systems

### Geneva (Switzerland) SDH System

Year: 2022

Irradiance /SF Energy Report [MWh]



**400**

MT-Power panels

**470**

MWh Delivered

**50 %**


Conversion

### Sondershausen (Germany) SDH System

Year: 2025

SONDERSHAUSEN, GERMANY (3.105 MT-POWER V4 SOLAR COLLECTORS - TVP SOLAR SA)  
EN ISO 24194:2022

- Total solar radiation on days valid for ISO 24194:2022 [MWh]
- Total Energy delivered to TES tank measured by Counter 202 [MWh]
- Energy production estimation according to ISO 24194:2022 [MWh]
- Daily yield measurement of the heat meter according to ISO 24194:2022 [MWh]
- Yearly PE ratio [%]
- Conversion of yearly energy radiation on days valid for ISO 24194:2022 [%]



**3.105**

MT-Power panels

**3.582**

MWh Delivered

**52 %**

Conversion

« I think having land  
and not ruining it is  
the most beautiful  
art that anybody  
could ever want »

- ANDY WARHOL -

**Thank you for your attention!**

